OHIGITAL (Red)

CITY OF PHILADELPHIA

DEPARTMENT OF LICENSES & INSPECTION

PHILADELPHIA, PA. 19107

CEASE OPERATIONS

YOU ARE HEREBY NOTIFIED THAT THIS LOCATION:

IS IN VIOLATION OF THE FIRE CODE AS NOTED BELOW:

E-2 CHENICAL CO., INC.

Failure to: Provide separation of acid storage and flammable liquid storage 5-505.--Clean entire premises. This work can be only done by an approved contractor. This building is to be vacated immediately 5-507 .-- Provide fire exiting 5-1402. -- Repair fire door 5-1403. -- Provide aisles space for emergency egrees 5-1302, -- Clean the building 5-3101, -- Provide electrical equipment 16 accordance with the National Biostrical Code 5-1605. -- Provide 2 remove exit from storage of flammables 5-1601 .-- Provide a separate room where Class I liquids are mixed or stored 5-1605, -- Hold fire drills and provide records 5-120 Protect combustible floors in chemical storage area 5-503. -- Thoroughly clean outside area 5-3109. -- Store hazardous chemicals in a dry place 5-503. -- Remove all defective containers 5-504. -- Provide volmetric capacity of all dike area 3-1609. -- Repair or replace defective or leaking piping 5-1609. -- Remove all !lammable liquid at base of tank 5-1609 .-- Remove water accumulation 5-1403 THE DEPARTMENT OF LICENSES AND INSPECTIONS HAS ORDERED OPERATIONS TO CEASE AT THESE PREMISES DUE TO SERIOUS FIRE CODE VIOLATIONS. THE PREMISES IS ORDERED VACATED IMMEDI-ATELY OF ALL EMPLOYEES, PATRONS, AND OCCUPANTS AND OCCUPANCY OF THESE PREMISES AFTER APPLIED 5, 1989 - INHEDIATELY IS ILLEGAL. ANY PERSON WHO PERMITS THE PREMISE 1 PE OCCUPIED AFTER THIS DATE OR WHO REMOVES, DAMAGES, OR DEFACES THIS CEASE OPERATIONS ORDER IS SUBJECT TO ARREST BY THE POLICE AND UPON CONVICTION TO A FINE OF UP TO \$300.00 AND/OR IMPRISONMENT OF UP TO NINETY (90) DAYS.

Barry R. Lebrart

DO NOT REMOVE THIS NOTICE

100057